

Oakley Hall - RE: CEI / NOV response

From: "Danny Brock" <dbrock@blomand.net>
To: "Oakley Hall" <Oakley.Hall@tn.gov>
Date: 12/17/2010 3:54 PM
Subject: RE: CEI / NOV response

1. Effluent valve on setting basin. Installed blind flange with gasket on effluent valve to eliminate discharge.
2. New math formula for calculating total suspended solids in being used.
3. Aluminum test is being sent to Environmental Science in Mt. Juliet, TN.
4. Total residual chlorine test parameter is being used.

Danny Brock

DB/jlv

From: Oakley Hall [mailto:Oakley.Hall@tn.gov]
Sent: Thursday, November 18, 2010 8:53 AM
To: dbrock@blomand.net; water1@blomand.net
Cc: Rob Howard
Subject: CEI / NOV response

Mr. Brock, the report is attached.

Thanks, woh

Wm. Oakley Hall